



**U.S. CPSC**   
 @USCPSC



**#Recall:** 37 million @KiddeSafety fire extinguishers can fail to activate during a fire. One death reported [bit.ly/2zbBvcs](http://bit.ly/2zbBvcs)

5:05 AM - Nov 2, 2017

2 181 90

# URGENT – Safety Message

Safety Management – Utility Group



What Happened: Kidde fire extinguisher failed, resulting in one death and additional 391 reports of Kidde fire extinguishers failing, resulting in sixteen injuries, including burns and smoke inhalation.

Safety Awareness And Conduct: Kiddie is recalling 37.8 million fire extinguishers sold in the United States plus 2.7 million in Canada. The company has set up a web page:

<https://inmarmarketaction.com/kidde/Kidde284US/>

Or call Kidde at (855)271-0773

Root Cause: Faulty plastic handles and push-buttons that become clogged



***“No Job is so important, and no service is so urgent, that we cannot take the time to perform our work...safely!”***

